FIRE EXTINGUISHER

TO BE PERFORMED MONTHLY

AIRCRAFT PORTABLE FIRE EXTINGUISHERS INSPECTION GUIDANCE

LOG

Frequency: CAP aircraft portable fire extinguishers shall be inspected when initially placed in service and thereafter each calendar month. Pilots or wing maintenance officers may perform this inspection and record it in the log provided below. All inspections shall be recorded.

PROCEDURES

Monthly inspections of aircraft fire extinguishers shall include a check ensuring the following items:

(a) Located in designated place and properly secured in the mounting bracket.
(b) No obstruction to access or visibility.
(c) Safety seals not broken or missing.
(d) Fullness determined by lifting or "hefting".
(e) No obvious physical damage, corrosion, leakage, or clogged nozzle.
(f) Pressure gage reading or indicator in the operable range or position.
(g) Operating instructions and manufacturer labeling legible and facing outward.

DATE INSPECTED			**NAME OF PERSON INSPECTING**
YEAR	**MONTH**	**DAY**	**Last, First MI.**

Aircraft Hand Portable Fire Extinguisher inspections are required IAW NFPA 408 & NFPA 10.